

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: 01

Dated: 07/03/2025

It is certified that an inspection team headed by **AJEE SINGH (AAE)**
(Name of Officers with designation) from **SDLW&TML, UJS Ramnagar** inspected the
Atal Utkrisht GIC Devipura Ramnagar Nainital (Name & Address of the school) on **05/03/2025**
(date of inspection) and on the basis of Water Test Report (Attached) bearing no. **07/SDLW&TML**
UJS/RN/2024-25 (PHED LAB) dated. **07/03/2025** certified that
the **Atal Utkrisht GIC Devipura Ramnagar Nainital** (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central State/ U.T. Govt.

This certificate is valid till 31.03.2026

Signature with Seal  **अमित अभियन्ता**
उत्तराखण्ड जल संस्थान

Name **AJEE SINGH**

Designation **AAE**

Name & Address of the Office/Department:
Ramnagar

To **AV GIC Devipura, Ramnagar**

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

* **Water Report Attached herewith**



Sub Divisional Level Water Quality Testing and Monitoring Laboratory Uttarakhand Jal Sansthan, Ramnagar

Phone No.: 05947-251350,

E-mail: eeram.ujs.uk@gmail.com

Report ID: 07/SDLWQTML/UJS /RN/2024-25

Date: 07/03/2025

Water Quality Test Report

Name & Address of Organization / Customer		Atal Utkrisht G.I.C Devipura Maldhanchaur, Ramnagar Nainital , Uttarakhand	
Product Description (Surface Water/Ground water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample Collected from Atal Utkrisht G.I.C Devipura Maldhanchaur, Ramnagar Nainital , Uttarakhand
Reference Sample Identification :	07/SDLWQTML/UJS/RN/2024-25	Date of Start of Analysis:	05/03/2025
		Date of End of Analysis:	07/03/2025
Date & Time of Sample Received: 05-03-2025&10:20 AM	Sample Collected By:	Customer	

Testing Details (A) Chemical Test

S.N.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH@25°C	7.41	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/l	331	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	1.02	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/l	240	200	600	IS 3025 Pt-23-2019
5.	Total Hardness (as CaCO ₃), mg/l	252	200	600	IS 3025 Pt-21-2002
6.	Calcium (as Ca), mg/l	57.6	75	200	IS 3025 Pt-40-2019
7.	Magnesium (as Mg), mg/l	26.2	30	100	APHA 23 rd Ed-3500-Mg-B:2017
8.	Chloride, mg/l	10.4	250	1000	IS 3025 Pt-32 : 2019
9.	Colour, Hazen	5	5	15	IS 3025 Pt-04 : 2021
10.	Residual Free Chlorine (FRC), mg/l	ND*	0.2	1.0	IS 3025 Pt-26:2021

(B) Bacteriological Test

11.	<i>E.coli</i>	ABSENT	Absent	Absent	APHA 23 rd -9223
-----	---------------	--------	--------	--------	-----------------------------

ND*: Not Detectable

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Quality Manager/ Executive Engineer
Maintenance Division
Uttarakhand Jal Sansthan
Ramnagar (Nainital)

Kamal
Incharge / Analyst
SDLWQTMLUJS Division
Technical Manager/Analyst
SDLWQTML, UJS, Ramnagar (Nainital)

End of Report

...to tested sample and applicable parameters. ... without permission of authority of testing laboratory.